

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7300-1615:0240

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: BOSCH SECURITY SYSTEMS, 130 Perinton Parkway, Fairport, NY 14450
Contact: Frank Mioduszewski (585) 678-3368 Fax (585) 678-3263
Email: frank.ski@us.bosch.com

DESIGN: MODEL ITS-DX4020-G communicator module. The GPRS/GSM IP Communicator enables two-way IP or dial communication over a commercial GPRS/GSM Network, intended for use with Bosch's Model D7212GV2, D742GV2, D9412GV2, and FPD-7024 Control Units, and Receiver Models D6600 and D6100I. The GPRS/GSM IP Communicator supports three modes of operation: IP over GPRS Mode, PSTN (Contact ID) over SM, and Dual Wireless Mode (IP over GPRS and PSTN (Contact ID) over GSM mode). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a control unit accessory intended for use with Bosch's Model D7212GV2 (CSFM Listing No. 07167-1615:100), D7412GV2 and D9412GV2, (CSFM Listing No. 07165-1615:119) and FPD-7024 (CSFM Listing No. 07165-1615:227) Control Units, and Receiver, Models D6600 (CSFM Listing No. 07300-1615:168) and D6100I (CSFM Listing No. 07300-1615:232). Refer to listee's Installation Instruction Manual for details.

06-07-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **June 09, 2010**

Listing Expires **June 30, 2010**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division